



GOVT. OF ARUNACHAL PRADESH
OFFICE OF THE SUPERINTENDENT OF
POLICE
EAST KAMENG DISTRICT
SEPPA

SP

NO.SPA/FS/INSP-23/2021-23

Dated Seppa the 31st Oct'2024

// PROVISIONAL NO OBJECTION CERTIFICATE //

Certified that after having inspection conducted by the Inspection Officer of Fire Station Seppa on 24/10/2024 and report submitted thereafter to this office of Fire Station, Seppa has No Objection to run the Govt. Higher Secondary School, Bazer Line - Seppa, subject to complied Fire prevention and Fire Safety requirements in accordance with APBBL-2019. This Certificate is valid for a period of 01 (one) year only from the date of Issue.

Condition for the validity of Fire Safety Certificate as under:-

1. All the fire Extinguishers must be in working condition.
2. Fire Safety drawing - 03 sets.
3. Questionnaires - 01 set.
4. Ground level water tank - 30,000 litres.
5. Hose Reel hose - 04 Nos.
6. Booster Pump (2 HP) - 01 No.
7. Apply for renewal of the NOC on two months prior to its expiry along with a copy of this certificate.

Hence, you are instructed above mentioned must be fulfilled in tenure period. After installation/preparation of the requisites you inform to the undersigned for further inspection.



Principal
Govt. Hr. Sec. School
Bazarline Seppa
East Kameng District (A.P)

*(Kamdam Sikom), APPS,
Superintendent of Police,
East Kameng District.*

*Superintendent of Police
East Kameng District
Seppa (Arunachal Pradesh).*